

ISTITUTO NAZIONALE DI RICERCA METROLOGICA Repository Istituzionale

Quantum differential ghost microscopy

This is the author's submitted version of the contribution published as:

Original

Quantum differential ghost microscopy / Losero, E.; Ruo-Berchera, I.; Meda, A.; Avella, A.; Sambataro, O.; Genovese, M.. - In: PHYSICAL REVIEW A. - ISSN 2469-9926. - 100:6(2019).
[10.1103/PhysRevA.100.063818]

Availability:

This version is available at: 11696/61265 since: 2021-02-12T10:56:36Z

Publisher:

APS

Published

DOI:10.1103/PhysRevA.100.063818

Terms of use:

This article is made available under terms and conditions as specified in the corresponding bibliographic description in the repository

Publisher copyright

American Physical Society (APS)

Copyright © American Physical Society (APS)

(Article begins on next page)

Quantum differential ghost microscopy

E. Losero,^{1,2} I. Ruò-Berchera,¹ A. Meda,¹ A. Avella,¹ O. Sambataro,³ and M. Genovese^{1,4}

¹*Istituto Nazionale di Ricerca Metrologica (INRIM), Strada delle Cacce 91, 10135 Torino, Italy*

²*Politecnico di Torino, C.so Duca degli Abruzzi 24, 10129 Torino, Italy*

³*Università degli Studi di Torino, Dipartimento di Fisica, Via P. Giuria 1, 10125 Torino, Italy*

⁴*INFN, sezione di Torino, via P. Giuria 1, 10125 Torino, Italy*

Quantum correlations become formidable tools for beating classical capacities of measurement. Preserving these advantages in practical systems, where experimental imperfections are unavoidable, is a challenge of the utmost importance. Here we propose and realize a novel quantum ghost imaging protocol stemming from the differential ghost imaging, a scheme elaborated so far in the limit of bright thermal light, particularly suitable in the relevant case of faint or sparse objects. The extension towards the quantum regime represents an important step as quantum correlations allow low brightness imaging, desirable for reducing the absorption dose. Furthermore, we optimize the protocol in terms of signal-to-noise ratio, to compensate for the detrimental effects of detection noise and losses. We perform the experiment using SPDC light in a microscope configuration. The image is reconstructed exploiting non-classical intensity correlation in the low photon flux regime, rather than photon pairs detection coincidences. On the one side, we validate the theoretical model and on the other we show the applicability of this technique by imaging biological samples.

Introduction

Ghost imaging (GI) was theoretically proposed in 1994 [1] and experimentally demonstrated by Pittman et al. one year later [2] by using quantum correlations generated by spontaneous parametric down conversion (SPDC). It was considered as the earliest quantum imaging technique [3], but soon it has been shown that also classical correlations, as present in split thermal beams, can be successfully exploited, although with smaller visibility [4–10]. Two spatially correlated beams are used: one is addressed to the object to be imaged and then to a bucket detector, namely a detector without spatial resolution, while the other is addressed directly to a spatially resolving detector, without interacting with the object. Neither of the two beams separately contains information on the object absorption profile, nevertheless it can be retrieved exploiting the correlation between them. Since based on the evaluation of second-order momenta of the joint distribution, GI is not a single-shot technique, instead it requires the acquisition of several frames and the signal-to-noise ratio (SNR) scales with the square root of the number of frames [11, 12].

Initially motivated by a fundamental debate on the boundary between classical and quantum resources, the attention toward GI is justified by the fact that it can be useful in various practical situations, as in the cases where environmental constraints do not allow placing fine optical system and pixelated detector behind the object [13], and because it is robust in presence of atmospheric turbulence or diffusive media on the object path [14–16].

Quantum photon number correlations, a tool of the utmost relevance in quantum technologies [3, 11, 12, 17–23], can add further advantages to GI as the possibility to probe the sample with a wavelength which differs from the one detected with spatial resolution [24, 25], in case

the first one is in a range where imaging system and spatial detection is technologically demanding. Moreover, quantum correlation allows retrieving ghost image at faint photon flux with a better SNR than by classical beams [25–27], where the stronger than classical correlation can be used also to reject external and detection noise [18, 27, 28].

Several variations of GI, aiming at increasing its applicability in realistic scenarios have been proposed, as for example back-scattering GI [29], computational GI [30, 31], compressive GI [32, 33].

Among them, the so called “differential GI” (DGI) proposed in 2010 by Ferri et al. [34] has received a large attention due to its relevant practical impact, addressing the problem of reconstructing small or faint objects in the field of view. In this situation the conventional GI typically fails because it requires an unaffordable number of acquisitions in order to reach a sufficiently high SNR. Proposed and experimentally realized only with bright thermal light [15, 34], DGI does not involve changes in the typical GI optical setup, rather a more efficient use of the available data. In particular also the integrated signal in the reference channel, from the spatially resolving detector, is used in the data elaboration.

In this work we study the performance of a DGI approach when exploiting quantum resources, motivated by their possible advantage in specific situations, for example in low brightness regime. We develop a comprehensive theoretical model of the SNR for both classical and quantum sources, which takes into account non idealities such as channels inefficiencies and electronic noise of the detector. It comes out that the brightness of the source, namely the number of photons per spatio-temporal mode, has a fundamental role in determining DGI performances, in terms of SNR, together with the photon losses. In particular, for low-brightness sources, the improvement pro-

vided by DGI is dramatically affected by photon losses, disappearing or becoming worse than GI for loss probability larger than 50%. These limitations of the DGI protocol cannot be derived from the classical description of Ref. [34], where correlated beams are treated as identical copies of the same classical stochastic process (an approximation that is suitable only in case of intense thermal beam).

However, we propose an optimized DGI protocol (ODGI) able to partially compensate for experimental imperfections, retrieving an advantage on GI for any value of losses and brightness. The only further requirement for its application is the characterization of channels efficiencies. This protocol can have positive impact where it is necessary to keep low the photon flux, as in X-ray GI [35, 36]. The optimization procedure stems from the one proposed and realized in the absorption estimation framework [37, 38].

For demonstrating the performances of this method, we perform an experiment using SPDC light in the low brightness regime. However, rather than basing the GI reconstruction on temporal coincidences among photon pairs, as in the typical approach of almost all GI experiments with quantum light, here we exploit non-classical intensity correlation certified by the evaluation of a specific non-classicality parameter known as noise reduction factor (NRF) [12, 39–42].

We validate the model comparing its prediction with the SNR experimentally estimated for the GI, DGI and the ODGI protocols. Besides that, in view of real application, a biological object, a $(285\mu\text{m})^2$ wasp wing detail, is reconstructed with spatial resolution of $5\mu\text{m}$.

Theory

We consider either equally split multi-mode thermal beam (*th*) or multi-mode twin-beam (*tw*) generated by SPDC. In both cases the two beams, used as probe and reference respectively, present spatial correlation [12]. In particular, referring to Fig. 1, the spatial selection performed in the reference beam by the pixel in $x_j^{(2)}$ automatically identifies a small area where the correlated probe photons are expected to impinge on the object plane, centered in $x_j^{(1)}$. This area represents the spatial resolution of any GI scheme. This can be obtained, for example, if the point-to-point far-field correlations of SPDC are imaged at the detection plane for the reference beam, while at the object plane for the probe beam. Similar condition can be obtained by pairs of correlated spatial modes in split pseudothermal beams. We further assume that the pixel is larger than the coherence area, so that the resolution cells identified by two adjacent pixels do not overlap. Given this one-to-one correspondence between object plane and reference detection plane, here-




FIG. 1: Scheme of GI and DGI protocols. Spatial correlations between two beams are exploited. The reference beam is detected by a spatial resolving detector, the probe beam, after interacting with the sample impinges on a detector without spatial resolution. Every pixel $x_j^{(2)}$ is in one-to-one correspondence with a resolution cell $x_j^{(1)}$ at the object plane. For the image reconstruction the number of photons detected by the bucket detector N_1 and the one detected by each pixel in the resolving detector, $n_2(x_j^{(2)})$, are used in the data elaboration. In DGI protocol (dashed path) also the integrated signal N_2 is exploited.

inafter we will omit the suffixes 1 and 2, identifying $x_j^{(2)}$ and $x_j^{(1)}$.

Each beam of the twin-beam follows thermal statistics, therefore there is no difference between the thermal and twin beam case when probe and reference beams are considered separately. In particular, the mean number of photons detected by the pixel in x_j is:

$$\langle \hat{n}_2(x_j) \rangle^{th} = \langle \hat{n}_2(x_j) \rangle^{tw} = n_2 \quad (1)$$

where we have assumed a spatially uniform beam. The corresponding number of photons passing through the resolution cell at the object plane and detected by the bucket is:

$$\langle \hat{n}_1(x_j) \rangle^{th} = \langle \hat{n}_1(x_j) \rangle^{tw} = n_2 t(x_j) \quad (2)$$

with $t(x_j)$ the mean transmission profile of the object in the resolution cell. Note that these expressions are obtained assuming the same loss level on the two channels in absence of the object $\eta_1 = \eta_2 = \eta$. This does not reduce the generality of our model since possible unbalancement between the channels can be included in the transmission profile of the object. When M spatio-temporal modes are collected per pixel per frame, the associated variances can be written as [12]:

$$\langle \delta^2 \hat{n}_2(x_j) \rangle^{th} = \langle \delta^2 \hat{n}_2(x_j) \rangle^{tw} = n_2(1 + n_2/M) + \Delta_{el}^2 \quad (3)$$

$$\begin{aligned} \langle \delta^2 \hat{n}_1(x_j) \rangle^{th} &= \langle \delta^2 \hat{n}_1(x_j) \rangle^{tw} = \\ n_2 t(x_j) (1 + n_2 t(x_j)/M) + \Delta_{el}^2 \end{aligned} \quad (4)$$

In Eq.s (3) and (4) we have taken into account the electronic noise of the detector, Δ_{el} . The crucial difference between thermal and twin beam case is in the covariance between two spatially correlated modes [12]:

$$\langle \delta \hat{n}_2(x_j) \delta \hat{n}_1(x_i) \rangle^{th} = \frac{t(x_i) n_2^2}{M} \delta_{i,j} \quad (5)$$

$$\langle \delta \hat{n}_2(x_j) \delta \hat{n}_1(x_i) \rangle^{tw} = t(x_i) \left(\frac{n_2^2}{M} + \eta n_2 \right) \delta_{i,j} \quad (6)$$

It is immediately clear that the correlation is always higher for SPDC light. The ratio of the two expressions is:

$$\frac{\langle \delta \hat{n}_2(x_j) \delta \hat{n}_1(x_j) \rangle^{tw}}{\langle \delta \hat{n}_2(x_j) \delta \hat{n}_1(x_j) \rangle^{th}} = 1 + \eta \frac{M}{n_2} \quad (7)$$

showing that the correlations, at the base of GI protocols, are significantly stronger for twin beam for small number of photons emitted per mode, $n_2 \ll \eta M$. It follows that, in this regime, only twin-beam light allows the object reconstruction in practical situations. In the opposite regime the performance of equally split thermal light and twin beam is asymptotically the same.

In the conventional GI protocol the transmission profile of the object is retrieved considering the covariance between each pixel of the reference channel $\hat{n}_2(x_j)$ and the bucket detector on the other channel, $\hat{N}_1 = \sum_{i=1}^{\mathcal{N}} \hat{n}_1(x_i)$, as represented in Fig. 1. Here, \mathcal{N} is the number of resolution cells at the object plane which corresponds to the number of pixels at the resolving detector. Indeed, from either Eq. (5) or Eq. (6) it comes out that for both thermal and twin beam case, the reconstructed image is:

$$S_{GI}(x_j) = \langle \delta \hat{N}_1 \delta \hat{n}_2(x_j) \rangle \propto t(x_j) \quad (8)$$

In [34], Ferri et al. propose the DGI protocol, where the bucket detector signal \hat{N}_1 is replaced by $\hat{N}_{DGI} = \hat{N}_1 - \frac{\langle \hat{N}_1 \rangle}{\langle \hat{N}_2 \rangle} \hat{N}_2$, with $\hat{N}_2 = \sum_{i=1}^{\mathcal{N}} \hat{n}_2(x_i)$ the integrated signal from the spatial resolving detector. This alternative protocol is depicted by the dashed path in Fig. 1. Note that $\langle \hat{N}_1 \rangle / \langle \hat{N}_2 \rangle = \bar{t}$, where \bar{t} is the average transmission of the object, i.e. $\bar{t} = (1/\mathcal{N}) \sum_{i=1}^{\mathcal{N}} t(x_i)$. For DGI the reconstructed image is given by:

$$S_{DGI}(x_j) = \langle \delta \hat{N}_{DGI} \delta \hat{n}_2(x_j) \rangle = S_{GI}(x_j) - \bar{t} \langle \delta^2 \hat{n}_2(x_j) \rangle \quad (9)$$

In the last equality we have used the fact that modes collected by different pixels of the resolving detector are

uncorrelated. Making use of Eq. (3, 5, 6) we get

$$S_{DGI}^{th}(x_j) = n_2 \left[\frac{n_2}{M} \delta t(x_j) - \bar{t} \right] \quad (10)$$

$$S_{DGI}^{tw}(x_j) = n_2 \left[\left(\frac{n_2}{M} + \eta \right) \delta t(x_j) - \bar{t}(1 - \eta) \right] \quad (11)$$

From Eq. (10), in the limit $n_2/M \gg 1$, one retrieves the main feature of DGI as proposed in [34], namely its sensitivity to the spatial change in the transmission of the object, $\delta t(x_j) = t(x_j) - \bar{t}$, rather than to the absolute value $t(x_j)$. This explains its significant advantages in the reconstruction of small or highly transparent objects. However, it is also clear that in the opposite regime of small number of photons detected per spatio temporal mode, the information on the transmission profile of the object is substantially lost. With twin beam, the transmission profile can be reconstructed even for $n_2/M \ll 1$, provided that the efficiency η is sufficiently high. Anyway, the possibility to practically get a faithful image is determined by the SNR. It is important to reduce the noise as much as possible on the reconstruction. For this reason, following the method developed in [37, 38], we propose a generalization of the DGI protocol by replacing \hat{N}_{DGI} with $\hat{N}_k = \hat{N}_1 - k \hat{N}_2$, leading to

$$S_k(x_j) = \langle \delta \hat{N}_k \delta \hat{n}_2(x_j) \rangle = S_{GI}(x_j) - k \langle \delta^2 \hat{n}_2(x_j) \rangle \quad (12)$$

where k is a constant that can be set in order to minimize the noise in the estimation of $S_k(x_j)$, approximately given by:

$$\begin{aligned} \delta^2 S_k(x_j) &\approx \langle \delta^2 \hat{N}_k \rangle \langle \delta^2 \hat{n}_2(x_j) \rangle \\ \langle \delta^2 \hat{N}_k \rangle &= \langle \delta^2 \hat{N}_1 \rangle + k^2 \langle \delta^2 \hat{N}_2 \rangle - 2k \langle \delta \hat{N}_1 \delta \hat{N}_2 \rangle \end{aligned} \quad (13)$$

For $k = 0$, i.e. for conventional GI, the variance reduces to $\delta^2 S_{GI}(x_j) = \langle \delta^2 \hat{N}_1 \rangle \langle \delta^2 \hat{n}_2(x_j) \rangle$ and making use of Eq. (3) and (4),

$$\delta^2 S_{GI}(x_j) = \mathcal{N} n_2^2 \left(\bar{t} + \frac{n_2}{M} \bar{t}^2 \right) \left(1 + \frac{n_2}{M} \right) \quad (14)$$

Eq. (14) shows that in the limit of $n_2/M \gg 1$ we find the same noise dependence from the mean transmittance squared reported in [34], although the general expression predicts a linear dependence in the opposite regime.

For the sake of simplicity, we focus on the case of a two level object, with $\epsilon \mathcal{N}$ resolution cells of transmission t_- and $(1 - \epsilon) \mathcal{N}$ of transmission t_+ . Therefore, ϵ represents the fraction of the detection area occupied by the lower transmittance portion of the object. Note that \bar{t} can be written in terms of $0 \leq \epsilon \leq 1$ as $\bar{t} = (1 - \epsilon) \mathcal{N} t_+ + \epsilon \mathcal{N} t_-$. Under these assumptions the SNR is defined as:

$$\text{SNR} = \frac{|\langle S_+ \rangle - \langle S_- \rangle|}{\sqrt{\delta^2 \langle S_+ \rangle + \delta^2 \langle S_- \rangle}}, \quad (15)$$

where $\langle S_{\pm} \rangle$ and $\delta^2 \langle S_{\pm} \rangle$ are respectively the mean value of the reconstructed image in correspondence of t_{\pm} and its associated variance. Considering $t_+ = 1$, $t_- = 0$ and no electronic noise, the SNR in the thermal and SPDC case for the GI protocol are:

$$\text{SNR}_{\text{GI}}^{th} = \sqrt{H} \frac{1}{\sqrt{2N(1-\epsilon)}} \frac{n_2}{n_2 + M}, \quad (16)$$

$$\text{SNR}_{\text{GI}}^{tw} = \sqrt{H} \frac{1}{\sqrt{2N(1-\epsilon)}} \frac{n_2 + M\eta}{n_2 + M} \quad (17)$$

Note that in this case ϵ simply becomes the fraction of the detection area occupied by the object. In the SNR expression the factor \sqrt{H} , being H the number of frames used to estimate S , simply comes from the central limit theorem, where the uncertainty on a mean value scales as \sqrt{H} , e.g. $\delta^2 \langle S(x_j) \rangle = \delta^2 S(x_j)/H$. From Eq.s (16)-(17) it emerges one of the weakness of the conventional GI, namely that for small ϵ the SNR drops down, making difficult the reconstruction of small objects in the field of view.

In Fig. 2 we report an example of GI reconstruction for a two level object, for different values of ϵ . From these reconstructions it is possible to experimentally estimate the SNR. $\langle S_{\pm} \rangle$ and $\delta^2 \langle S_{\pm} \rangle$ are estimated as the mean value and the variance on the reconstructed images, in correspondence of the regions of transmittance t_{\pm} respectively. It can be appreciated how the object, a totally absorbing deposition on the right side of the field of view, better emerges from the noise as ϵ increases.




FIG. 2: Experimental GI reconstructions of a binary object ($t_+ = 1$, $t_- = 0$) for $N = 952$ and $H = 2000$, using SPDC light. The object consists in a totally absorbing deposition occupying a variable fraction ϵ of the reconstructed area. Different values of ϵ are considered and the corresponding SNR estimated; for small ϵ , e.g. $\epsilon = 0.18$, $\text{SNR} < 1$ and the deposition on the right side is almost hidden in the noise.

This issue of the conventional GI can be overcome by considering the generalized protocol $S_k(x_j)$. Indeed,

from Eq. (13) we argue that exploiting the spatial correlations between the two beams, i.e. $\langle \delta \hat{N}_1 \delta \hat{N}_2 \rangle \neq 0$, and choosing k appropriately, the noise can be reduced. This idea is at the basis of the optimization procedure we implemented. In particular, we maximize the SNR respect to k , and define the ODGI protocol as:

$$S_{\text{ODGI}}(x_j) = S_{k_{opt}}(x_j) = \langle \delta \hat{N}_{opt} \delta \hat{n}_2(x_j) \rangle, \quad (18)$$

$$\hat{N}_{opt} = \hat{N}_1 - k_{opt} \hat{N}_2.$$

The general expression for k_{opt} , in the twin-beam case, is:

$$k_{opt}^{tw} = \frac{n_2(n_2 + M\eta)\bar{t}}{n_2^2 + M(n_2 + \Delta_{el}^2)} \quad (19)$$

while for the thermal case a similar expression holds but without the term $M\eta$ at the numerator. Focusing on the twin-beam case, we have:

$$n_2/M \gg 1 : k_{opt}^{tw} = \bar{t} = \frac{\langle \hat{N}_1 \rangle}{\langle \hat{N}_2 \rangle} \quad (20)$$

$$n_2/M \ll \eta : k_{opt}^{tw} = \frac{n_2}{n_2 + \Delta_{el}^2} \eta \cdot \frac{\langle \hat{N}_1 \rangle}{\langle \hat{N}_2 \rangle} \quad (21)$$

Eq. (20) shows that for high number of detected photons per mode S_{ODGI} coincides with S_{DGI} . Remarkably, in this case k_{opt} does not depend on experimental imperfections.

For low brightness sources, as shown in Eq. (21), S_{DGI} coincides with S_{ODGI}^{tw} only in the ideal case of $\eta = 1$ and $\Delta_{el} = 0$; in all other cases ODGI performs better. However, in order to evaluate k_{opt}^{tw} , absolute values of the channel efficiency η and the detection noise Δ_{el} should be known [38, 44].

The improvement offered by DGI versus the conventional GI protocol can be quantified in terms of SNR. For the sake of simplicity we report the expressions neglecting the electronic noise, namely $\Delta_{el}^2 \ll n_2$, and considering a binary object ($t_+ = 1$, $t_- = 0$):

$$n_2/M \gg 1/\epsilon : \frac{\text{SNR}_{\text{DGI}}^{tw}}{\text{SNR}_{\text{GI}}^{tw}} = \frac{\text{SNR}_{\text{DGI}}^{th}}{\text{SNR}_{\text{GI}}^{th}} = \frac{1}{\sqrt{\epsilon}} \quad (22)$$

$$n_2/M \ll 1 : \frac{\text{SNR}_{\text{DGI}}^{tw}}{\text{SNR}_{\text{GI}}^{tw}} = \frac{1}{\sqrt{2(\eta - \frac{1}{2})(\epsilon - 1) + 1}} \quad (23)$$

These results can be graphically appreciated in Fig. 3. In the high-intensity regime, corresponding to Eq. (22) and reported in Fig. 3a, SPDC and thermal light show the same performance and the SNRs for both GI and DGI are independent from the channel efficiency. Note that the validity condition of Eq. (22) requires higher and higher values of detected photons per mode as ϵ decreases. For small ϵ the DGI advantage is relevant, an extremely interesting feature in view of real applications.




FIG. 3: SNR, normalized per the number of frames H and the number of pixels in the reconstructed area \mathcal{N} , in function of the object occupation fraction ϵ , for different values of the channel efficiency η ($t_+ = 1$, $t_- = 0$, $\Delta_{el} = 0$). (a) High brightness regime. (b) Low brightness regime, twin-beam case.

On the contrary, losses in the low intensity regime have a significant impact. From Eq. (23) comes out that, despite we find the same result of Eq. (22) for $\eta = 1$, the improvements offered by DGI over GI decreases with losses. In particular, for $\eta < 1/2$, DGI performs even worse than the conventional protocol. The dependence of the SNR from the channel efficiency, at low brightness, is evident in Fig. 3(b).

The ODGI protocol can partially compensate for losses, in particular:

$$n_2/M \ll \eta : \frac{\text{SNR}_{\text{ODGI}}^{tw}}{\text{SNR}_{\text{GI}}^{tw}} = \frac{1}{\sqrt{\eta^2(\epsilon - 1) + 1}} \quad (24)$$

From Eq. (24) it emerges that, for low brightness sources,

ODGI performs always better than the conventional GI, but it is also permanently better than DGI, as it emerges comparing Eq. (24) with Eq. (23). Note that in these equations we don't report the expressions for thermal light since in this regime thermal correlations are order of magnitude weaker than for twin-beam light (see Eq. (7)), thus requiring an unfeasable number of frames for achieving a sufficiently high SNR.

The general performance of DGI and ODGI with respect to conventional GI, for the SPDC case, is reported in Fig. 4 in function of the channel efficiency η and the number of detected photons per mode n_2/M , fixing $\epsilon = 0.1$. Considering the front plane, corresponding to $n_2/M = 0.01$, one can observe that the highest ODGI advantage over both the other protocols occurs when $\text{SNR}_{\text{DGI}}^{tw} = \text{SNR}_{\text{GI}}^{tw}$, i.e. for $\eta \sim 0.5$. Moreover, it emerges that increasing the brightness of the source allows obtaining an advantage with respect to GI for lower value of the channels efficiency η , so that, depending on the experimental condition, the optimal trade-off can be designed.




FIG. 4: DGI and ODGI are compared in terms of SNR with GI, at varying both the channel efficiency η and the number of detected photons per mode n_2/M . The surfaces are obtained for the twin-beam case, considering a binary object ($t_+ = 1$, $t_- = 0$) and $\epsilon = 0.1$.

Experiment

Here we present an experiment comparing GI, DGI and ODGI protocols in the low brightness regime using twin-beam generated by SPDC.

The experimental set-up is reported in Fig. 5. A twin-beam state with degeneracy wavelength $\lambda_1 = \lambda_2 = 810\text{nm}$ is produced pumping a 1cm Type-II-Beta-Barium-Borate (BBO) non linear crystal with a CW laser-beam (100mW at $\lambda_p = 405\text{nm}$). In this process, with a certain small probability, a photon of the pump is down-converted into two photons. The momentum conservation implies that the two downconverted photons




FIG. 5: Scheme of the experimental set-up. In the BBO crystal two beams with perfect correlation in the photon number (twin-beam state) are generated. The probe beam interacts with the sample and is detected by a half of a CCD camera chip, while the other beam goes directly to the second half of the chip. The equivalent bucket detector on both channels are simulated by integrating (summing pixels signal) over the two regions. Two different samples are used: a set of uniform depositions of different transmittance t_- and a biological object, i.e. a wasp wing.

emerge with opposite transverse momenta $\mathbf{q}_1 = -\mathbf{q}_2$. In the far field of the emission, realized at the focal plane of a lens with $f_{FF} = 1\text{cm}$, momentum correlation is mapped in position correlation, $\mathbf{x}_1 = -\mathbf{x}_2$, with $\mathbf{x}_i = \frac{\lambda_i \mathbf{q}_i f_{FF}}{2\pi}$. To detect only photons around the degeneracy and to cut the pump, an interference filter with 20nm bandwidth centered at 800nm is placed after the crystal. To take advantage of the point-to-point far-field correlations, the object is placed directly at the focal plane of the f_{FF} lens, and a second lens with focal length $f_{IM} = 1.6\text{cm}$, is used to image this plane to the camera sensor, with a magnification factor $M = 7.8$.

The detector is a charge-coupled-device (CCD) camera Princeton Inst. Pixis 400BR Excelon operating in linear mode, i.e. the signal is proportional to the incident number of photon (intensity) in the acquisition time, and cooled down to -70°C . It presents high quantum efficiency, nominally $> 95\%$ at 810nm, 100% fill factor and low noise (read-noise has been estimated to be $\Delta_{el} = 5e^-/(\text{pixel} \cdot \text{frame})$ at 100kHz acquisition rate, and $\Delta_{el} = 13e^-/(\text{pixel} \cdot \text{frame})$ when the higher 2MHz digitization rate is used). The detector area measures $(13.3\text{mm})^2$ and the size of a physical pixel is $13\text{ }\mu\text{m}$, nevertheless for this experiment we use 3×3 hardware binning. It is known that the ultimate resolution achievable in ghost imaging is given by the second order coherence area of the light at the object plane. In particular, following the procedure in [43], we estimated this coherence area to be $(5\text{ }\mu\text{m})^2$. The binned pixel size corresponds roughly to the coherence area, taking into account the 7.8 magnification factor from the object plane to the detection plane, so that pixels collect independent optical mode thus remaining statistically uncorrelated to each other. Note that in our experimental configuration there is no physical bucket detector. The equivalent bucket de-

tectors on both the beams are simulated by integrating over the respective regions of the sensor.

The average number of photons detected per pixel per frame is $n_2 \sim 10^3$ and the corresponding number of modes is $M = M_{sp} M_{temp}$, where M_{sp} and M_{temp} are the number of spatial and temporal modes. Being the acquisition time of a single frame 50 ms, and the coherence time of the SPDC process around 10^{-12}s , it follows $M_{temp} \sim 5 \cdot 10^{10}$. The dimension of a binned pixel is chosen in order to have $M_{sp} \sim 1$ incident. It follows that the condition of very low brightness is fulfilled: $n_2/M \sim 2 \cdot 10^{-8} \ll \eta$.

In order to demonstrate the non-classicality of the detected intensity correlation, we evaluate the NRF parameter defined as $\text{NRF} = \langle \Delta^2(\hat{n}_1 - \hat{n}_2) \rangle / \langle \hat{n}_1 + \hat{n}_2 \rangle$, that is the variance of the photon number difference between a pair of correlated pixels normalized by their sum (the shot noise bound). Only non-classical correlation allows to have $0 < \text{NRF} < 1$ [3, 12]. In our case we estimated $\text{NRF} = 0.77 \pm 0.02$. Note that NRF, in our setup, depends on the pixel size with respect to the coherence area, thus it is possible to reach lower value of NRF integrating the signals over larger areas. However, this is not the scope of the present work.

To experimentally validate the theoretical model we image four different objects, each of them presenting two levels of transmittance ($t_+ \sim 1$ for all cases, $t_- = 0, 0.25, 0.34, 0.52$ respectively). These samples consist in a AR-coated glass-slide with thin metallic depositions. For each sample $3 \cdot 10^4$ frames are acquired at 100 kHz acquisition rate. In the data processing, a cropped region of $\mathcal{N} = 28 \times 34$ binned pixels is reconstructed, including each time an increasing fraction ϵ of the low transmittance part of the object. The reconstruction is performed using the three different protocols S_{GI} , S_{DGI} , S_{ODGI} . An example of the corresponding reconstructions is presented in Fig. 2 in case of the conventional GI. The dependence of SNR, in Eq. (15), from ϵ is evaluated performing spatial statistics on this kind of images.

Fig. 6 (a) and (b) report the results for two different transmittances, $t_- = 0$ and $t_- = 0.52$ respectively. The dashed lines are obtained fitting the experimental data with the theoretical model, considering η as free parameter.

In Fig. 7, at fixed $\epsilon = 0.52$, the SNR for different t_- is reported. Also, in this case data are fitted using the theoretical curves with the efficiency η as free parameter.

For comparing the three protocols in presence of higher losses a neutral filter is placed on the twin-beam path. Two different values of channel efficiency are considered: $\eta \sim 0.5$ and $\eta \sim 0.3$. The results corresponding to these experimental situations are reported in Figs 8 and 9 respectively. In particular for $\eta = 0.3$, the DGI protocol performs worse than the conventional one, while the ODGI always offers an advantage.

In all the cases considered, see Figs 6-7-8-9, the curves




FIG. 6: SNR in function of ϵ , the fraction of the detection area occupied by the deposition, for (a) $t_- = 0$ and (b) $t_- = 0.52$. Green color refers to GI, purple to DGI and yellow to ODGI. The dots are the experimental data, obtained for $H \sim 3 \cdot 10^4$ frames and an area of $\mathcal{N} = 952$ pixels. The dashed lines are obtained fitting the data with the theoretical model, considering η as free parameter. The confidence region at 1σ is also reported as colored bands around the curves.

fit the experimental data properly, falling almost all the data in the 1σ confidence region. A further element of consistency of the model is the accordance between the value of η obtained from the fit and the one independently estimated with the absolute technique described in [43–46], which extends the Klyshko method [47, 48]. Indeed, referring for example to Fig. 6 (a), the values of η obtained from the fit and their standard uncertainty are: $\eta_{GI} = 0.798 \pm 0.004$, $\eta_{DGI} = 0.786 \pm 0.003$, $\eta_{ODGI} = 0.786 \pm 0.003$, being the value independently estimated $\eta = 0.794 \pm 0.003$. The values are compatible with a confidence level of 95%. Analogous results are obtained in all the other fits.

Finally, in order to demonstrate that our system can be interesting in view of real application, two different biological samples are imaged, in particular, a *polistes* wasp wing and a green bug wing. The details cover a region of $\mathcal{N} = 57 \times 57$ binned pixels, corresponding to




FIG. 7: SNR in function of t_- , fixed $\epsilon = 0.52$. Green color refers to GI, purple to DGI and yellow to ODGI. The dots are the experimental data, obtained for $H \sim 3 \cdot 10^4$ frames and an area of $\mathcal{N} = 952$ pixels. The dashed lines are obtained fitting the data with the theoretical model, considering η as free parameter. The confidence region at 1σ is also reported as colored bands around the curves.




FIG. 8: SNR in function of ϵ , for $\eta \sim 0.5$. Green color refers to GI, purple to DGI and yellow to ODGI. The dots are the experimental data, obtained acquiring $H \sim 3 \cdot 10^4$ frames and considering an area of $\mathcal{N} = 952$ pixels. The dashed lines are obtained fitting the data with the theoretical model, considering η as free parameter. The confidence region at 1σ is also reported as colored bands around the curves.

an area of $(285\mu\text{m})^2$ in the object plane. The resolution achieved with our set-up is $5\mu\text{m}$, corresponding to the size of the second order coherence area at the object plane reached in the actual setup. The resolution is not the main concerns of our paper, focused on the SNR, but we mention that it is aligned with other recent ghost microscopy experiment [25]. In Fig. 10 the *polistes* wasp wing reconstructions, obtained for $2 \cdot 10^5$ frames acquired at 2MHz, are reported. Fig. 10(a) is the direct image. To obtain the reconstructed images via S_{GI} and S_{ODGI} , in Fig. 10(b)-(c) respectively, the total region is divided into




FIG. 9: SNR in function of ϵ , for $\eta \sim 0.3$. Green color refers to GI, purple to DGI and yellow to ODGI. The dots are the experimental data, obtained acquiring $H \sim 3.5 \cdot 10^4$ frames and considering an area of $\mathcal{N} = 525$ pixels. The dashed lines are obtained fitting the data with the theoretical model, considering η as free parameter. The confidence region at 1σ is also reported as colored bands around the curves.




FIG. 10: Images of a wasp wing with spatial resolution of $(5\mu\text{m})^2$. (a) direct image, obtained averaging 5000 frames. (b)-(c) reconstruction using the GI and ODGI protocol respectively. The total region is divided into 9 sub-region, the protocol is applied to each of them and finally the complete image is recovered. 40 block of 5000 images acquired at 2MHz are processed.

9 sub-regions and the protocol applied to each of them. At this digitization rate the presence of higher electronic noise lowers the improvement offered by ODGI, by the way few more details can be appreciated in Fig. 10(c) rather than in Fig. 10(b) (see for example the increased visibility of the edge of the wing in the left side). In Fig. 11(b) the reconstruction of the green bug wing is shown (Fig. 11(a) is the direct image). In this case we acquired $4 \cdot 10^4$ frames at 100 kHz. In particular, in Fig. 11(c)-(d) we report the reconstruction of two different details. In Fig. 11(c), the edge of the wing is more defined when using S_{ODGI} with respect to the conventional protocol. In Fig. 11(d) the S_{GI} and S_{ODGI} reconstructions of a second detail are reported for different number of frames: it can be appreciated that using the ODGI protocol the spot emerges from the noise for a lower number of frames.




FIG. 11: Images of a green bug wing with spatial resolution of $(5\mu\text{m})^2$. (a) direct image, obtained averaging 5000 frames. (b) reconstruction using the ODGI protocol. The total region is divided into 9 sub-region, the protocol is applied to each of them and finally the complete image is recovered. 8 blocks of 5000 images acquired at 100 kHz are processed. (c) S_{GI} and S_{ODGI} reconstruction of the border detail squared in (a). (d) S_{GI} and S_{ODGI} reconstruction of the spot detail squared in (a). The reconstruction for different number of frames is reported.

In particular, note that the detail for 40.000 frames using S_{GI} is comparable with the one obtained for 20.000 by S_{ODGI} . This result is in agreement with the prediction of our model for these specific conditions. This means that the photon dose can be reduced of a factor 2 while providing the same information, an important improvement when considering delicate samples (e.g. for X-ray ghost imaging).

Conclusion

In this work, we extended the differential ghost imaging protocol [34] in the unexplored regime of low brightness sources and quantum correlation. The attention toward the DGI is justified since it offers significant SNR improvements over the conventional GI, in particular in presence of small or highly transparent objects. However, this advantage has been demonstrated in previous works within the implicit assumption of classical intense thermal beams. In this paper in particular we point to the investigation of the low-intensity regime, including

quantum resources, which is of great interest since there are practical situations where it is worth to keep low the photon dose, e.g. biological, delicate or photo-sensitive samples. For example, this represents an issue in X-ray imaging and spectroscopy [35, 36]. We note that in this contest, improving the SNR performance at fixed exposure time, i.e. without increasing the photon dose, is of utmost importance.

A theoretical model in terms of experimental quantities has been developed, both for thermal and SPDC light, for any value of the source brightness. Also experimental imperfections such as losses and electronic noise in the detector has been considered. It comes out that DGI performances in the regime of small number of photons per spatio temporal mode ($n_2/M \ll \eta$) are highly affected from experimental imperfections. For example, the DGI advantage in terms of SNR is almost washed away even for relatively high efficiency as the one in our set-up, $\eta = 0.8$ and the model shows that for lower efficiencies, namely $\eta < 0.5$, DGI is worse than GI.

Therefore, inspired by what done in the absorption estimation framework in [37], we propose an optimized protocol (ODGI) able to partially compensate for detrimental effects of experimental imperfections such as channel efficiencies and electronic noise, but requiring their estimation. In the high brightness regime ODGI is always equivalent to the original DGI protocol. In the opposite, low brightness, case it coincides with DGI when $\eta = 1$ while in the realistic condition of $\eta < 1$ it performs always better than both DGI and GI.

The theoretical model has been experimentally validated in the low brightness regime using quantum correlated beams produced by SPDC. The number of photons collected per pixel was $n_2 \sim 10^3$: this regime allows to reconstruct the images by performing intensity correlations, without the need of any time-coincidence scheme. Finally, in view of possible real applications, the optimized protocol has been successfully employed in the reconstruction of a complex biological object, demonstrating that a reduction of the photon dose is possible while maintaining the same SNR of the conventional GI protocol.

Acknowledgments

The authors acknowledge the European Unions Horizon 2020 and the EMPIR Participating States in the context of the project 17FUN01 BeCOMe for financial support. The authors also thank Matteo Fretto which realized the absorbing samples used.

Author Contributions

IRB and EL conceived the idea and developed the theoretical model of this work, that was discussed and designed with inputs by all authors. EL, AM, AA and OS realized the experimental setup and collected the data in INRIM quantum optics labs (coordinated by MG). All authors discussed the results and contributed to the writing of the paper.

Conflicts of interest

There are no conflicts of interest.

-
- [1] Belinskii, A. & Klyshko, D. Two-photon optics: diffraction, holography, and transformation of two-dimensional signals. *Sov. Phys. JETP* **78**, 259 (1994).
 - [2] Pittman, T. B., Shih, Y. H., Strekalov, D. V. & Sergienko, A. V. Optical imaging by means of two-photon quantum entanglement. *Phys. Rev. A* **52**, R3429-32 (1995).
 - [3] Ruo-Berchera, I. & Degiovanni, I. P. Quantum imaging with sub-Poissonian light: challenges and perspectives in optical metrology. *Metrologia* **56**, 024001 (2019).
 - [4] Gatti, A., Brambilla, E., Bache, M. & Lugiato, L. A. Ghost Imaging with Thermal Light: Comparing Entanglement and Classical Correlation. *Phys. Rev. Lett.* **93**, 093602 (2004).
 - [5] Ferri, F., Magatti, D., Gatti, A., Bache, M., Brambilla, E. & Lugiato, L. A. High-Resolution Ghost Image and Ghost Diffraction Experiments with Thermal Light. *Phys. Rev. Lett.* **94**, 183602 (2005).
 - [6] Valencia, A., Scarcelli, G., D'Angelo, M. & Shih, Y. Two-Photon Imaging with Thermal Light. *Phys. Rev. Lett.* **94**, 063601 (2005).
 - [7] Chen, X. H., Agafonov, I. N., Luo, K. H., Liu, Q., Xian, R., Chekhova, M. V. & Wu, L. A. High-visibility, high-order lensless ghost imaging with thermal light. *Opt. Lett.* **35**, 1166-8 (2010).
 - [8] Zhai, Y.H., Chen, X.H., Zhang, D. & Wu, L.A. Two-photon interference with true thermal light. *Phys. Rev. A* **72**, 043805 (2005).
 - [9] Hartmann, S., Molitor, A. & Elsassner, W. Ultrabroadband ghost imaging exploiting optoelectronic amplified spontaneous emission and two-photon detection. *Opt. Lett.* **40**(24), 5770-5773 (2015).
 - [10] Shapiro, J. H. & Boyd, R. W. The physics of ghost imaging. *Quantum Inf. Process.* **11**, 949 (2012).
 - [11] Genovese, M. Real applications of quantum imaging. *Journ. of Opt.* **18**, 073002 (2016).
 - [12] Meda, A., Losero, E., Samantaray, N., Scafrimuto, F., Pradyumna, S., Avella, A., Ruo-Berchera, I. & Genovese, M. Photon-number correlation for quantum enhanced imaging and sensing. *Jour. of Opt.* **19**(9), 094002 (2017).
 - [13] Meda, A., Caprile, A., Avella, A., Ruo-Berchera, I., Degiovanni, I. P., Magni A & Genovese, M. Magneto-optical

- imaging technique for hostile environments: The ghost imaging approach. *Appl. Phys. Lett.* **106**, 262405 (2015).
- [14] Gong, W. & Han, S. Correlated imaging in scattering media. *Opt. Lett.* **36**, 394-396 (2011).
- [15] Bina, M., Magatti, D., Molteni, M., Gatti, A., Lugiato, L. A. & Ferri, F. Backscattering differential ghost imaging in turbid media. *Phys. Rev. Lett.* **110**, 083901 (2013).
- [16] Meyers, R. E., Deacon, K. S., Tunick, A. D. & Shih, Y. Virtual ghost imaging through turbulence and obscurants using Bessel beam illumination. *Appl. Phys. Lett.* **100**, 061126 (2012).
- [17] Monticone, D.G., Katamadze, K., Traina, P., Moreva, E., Forneris, J., Rufo-Berchera, I., Olivero, P., Degiovanni, I.P., Brida, G. & Genovese, M. Beating the Abbe diffraction limit in confocal microscopy via nonclassical photon statistics. *Phys. Rev. Lett.* **113**(14), 143602 (2014).
- [18] Lopaeva, E.D., Rufo-Berchera, I., Degiovanni, I.P., Olivares, S., Brida, G. & Genovese, M. Experimental realization of quantum illumination. *Phys. Rev. Lett.* **110**(15), 153603 (2013).
- [19] Brida, G., Genovese, M. & Rufo-Berchera, I. Experimental realization of sub-shot-noise quantum imaging. *Nat. Photon.* **4**(4), 227 (2010).
- [20] Pradyumna S.T. et al. *Quantum-enhanced correlated interferometry for fundamental physics tests*, arXiv:1810.13386
- [21] Knyazev, E., Khalili, F.Y. & Chekhova, M.V. Overcoming inefficient detection in sub-shot-noise absorption measurement and imaging. *Opt. Expr.* **27**(6), 7868-7885 (2019).
- [22] Zhang, Z., Tengner, M., Zhong, T., Wong, F.N. & Shapiro, J.H. Entanglements benefit survives an entanglement-breaking channel. *Phys. Rev. Lett.* **111**(1), 010501 (2013).
- [23] Perina Jr, J., Haderka, O., Allevi, A. & Bondani, M. Absolute calibration of photon-number-resolving detectors with an analog output using twin beams. *Appl. Phys. Lett.* **104**(4) 041113 (2014).
- [24] Chan, KamWai Clifford, OSullivan, M. N., & Boyd, R. W. Two-color ghost imaging. *Physical Review A* **79**(3), 033808 (2009).
- [25] Aspden, R. S. et al. Photon-sparse microscopy: visible light imaging using infrared illumination. *Optica* **2**(12), 1049-1052 (2015).
- [26] Brida, G. et al. Systematic analysis of signal-to-noise ratio in bipartite ghost imaging with classical and quantum light. *Phys. Rev. A* **83**, 063807 (2011).
- [27] Morris, P. A. et al. Imaging with a small number of photons. *Nat. Commun.* **6**, 5913 (2011).
- [28] Kalashnikov, D. A., Pan, Z., Kuznetsov, A. I. & Krivitsky, L. A. Quantum spectroscopy of plasmonic nanostructures. *Phys. Rev. X* **4**, 011049 (2014).
- [29] Meyers, R., Deacon, K.S. & Shih, Y. Ghost-imaging experiment by measuring reflected photons. *Phys. Rev. A* **77**(4), 041801 (2008).
- [30] Shapiro, J.H. Computational ghost imaging. *Phys. Rev. A* **78**, 061802(R) (2008).
- [31] Bromberg, Y., Katz, O., Silberberg, Y. Ghost imaging with a single detector. *Phys. Rev. A* **79**, 053840 (2009).
- [32] Katz, O., Bromberg, Y. & Silberberg, Y. Compressive ghost imaging. *Appl. Phys. Lett.* **95**, 131110 (2009).
- [33] Yu, W. Adaptive compressive ghost imaging based on wavelet trees and sparse representation. *Opt. Expr.* **22**, 7133 (2014).
- [34] Ferri, F., Magatti, D., Lugiato, L.A. & Gatti, A. Differential ghost imaging. *Phys. Rev. Lett.* **104**(25), 253603 (2010).
- [35] Zhang, A. X., He, Y. H., Wu, L. A., Chen, L. M. & Wang, B. B. Tabletop x-ray ghost imaging with ultralow radiation. *Optica* **5**(4), 374-377 (2018).
- [36] Schori, A. & S. Schwartz. X-ray ghost imaging with a laboratory source. *Opt. Expr.* **25**(13), 14822-14828 (2017).
- [37] Moreau, P. A. et al. Demonstrating an absolute quantum advantage in direct absorption measurement. *Scient. Rep.* **7**, 6256 (2017).
- [38] Losero, E., Rufo-Berchera, I., Meda, A., Avella, A. & Genovese, M. Unbiased estimation of an optical loss at the ultimate quantum limit with twin-beams. *Scient. Rep.* **8**(1), 7431 (2018).
- [39] Brida, G., Caspani, L., Gatti, A., Genovese, M., Meda, A., & Rufo-Berchera, I. Measurement of sub-shot-noise spatial correlations without background subtraction. *Phys. Rev. Lett.*, **102**(21), 213602 (2009).
- [40] Bondani, M. and Allevi, A. Can nonclassical correlations survive in the presence of asymmetric lossy channels? *The European Physical Journal D* **72**(10), 178 (2018).
- [41] Perina, J Jr., Michlek, V and Haderka, O. Reconstruction of Joint Photon-Number Distributions of Twin Beams Incorporating Spatial Noise Reduction *Phys. Rev. Applied*, **10**, 064054, (2018).
- [42] Iskhakov, T. S., Usenko, V. C., Filip, R., Chekhova, M. V. and Leuchs, G. Low-noise macroscopic twin beams, *Phys. Rev. A*, **93** 043849 (2016).
- [43] Meda, A., Rufo-Berchera, I., Degiovanni, I.P., Brida, G., Rastello, M.L. & Genovese, M. Absolute calibration of a charge-coupled device camera with twin beams. *Appl. Phys. Lett.* **105**(10), 101113 (2014).
- [44] A. Avella, I. Rufo-Berchera, I. P. Degiovanni, G. Brida, & Genovese, M. Absolute calibration of an EMCCD camera by quantum correlation, linking photon counting to the analog regime. *Opt. Lett.* **41**, 1841-1844 (2016).
- [45] Brida, G. et al. Possibility of absolute calibration of analog detectors by using parametric downconversion: a systematic study. *JOSA B* **23**, 2185 (2006).
- [46] Brida, G., Degiovanni, I. P., Genovese, M., Rastello, M. L. & Rufo-Berchera, I. Detection of multimode spatial correlation in PDC and application to the absolute calibration of a CCD camera. *Opt. Expr.* **18**, 20572-20584 (2010).
- [47] Brida, G., Castelletto, S., Degiovanni, I. P., Novero, C., & Rastello, M.L. Quantum efficiency and dead time of single-photon counting photodiodes: a comparison between two measurement techniques. *Metrologia* **37**, 625 (2000).
- [48] Klyshko, D.N. Use of two-photon light for absolute calibration of photoelectric detectors. *Soviet Journal of Quantum Electronics* **10**(9), 1112 (1980).