



## ISTITUTO NAZIONALE DI RICERCA METROLOGICA Repository Istituzionale

Mapping the conductivity of graphene with Electrical Resistance Tomography

*Original*

Mapping the conductivity of graphene with Electrical Resistance Tomography / Cultrera, Alessandro; Serazio, Danilo; Zurutuza, Amaia; Centeno, Alba; Txoperena, Oihana; Etayo, David; Cordon, Alvaro; Redo-Sanchez, Albert; Arnedo, Israel; Ortolano, Massimo; Callegaro, Luca. - In: SCIENTIFIC REPORTS. - ISSN 2045-2322. - 9:1(2019), p. 10655. [10.1038/s41598-019-46713-8]

*Availability:*

This version is available at: 11696/61087 since: 2020-01-29T10:33:52Z

*Publisher:*

Nature Publishing Group

*Published*

DOI:10.1038/s41598-019-46713-8

*Terms of use:*

This article is made available under terms and conditions as specified in the corresponding bibliographic description in the repository

*Publisher copyright*

(Article begins on next page)

# SCIENTIFIC REPORTS



OPEN

## Mapping the conductivity of graphene with Electrical Resistance Tomography

Alessandro Cultrera<sup>1</sup>, Danilo Serazio<sup>1</sup>, Amaia Zurutuza<sup>2</sup>, Alba Centeno<sup>2</sup>, Oihana Txoperena<sup>2</sup>, David Etayo<sup>3</sup>, Alvaro Cordon<sup>3</sup>, Albert Redo-Sanchez<sup>3</sup>, Israel Arnedo<sup>4</sup>, Massimo Ortolano<sup>1,5</sup> & Luca Callegaro<sup>1</sup>

Electronic applications of large-area graphene films require rapid and accurate methods to map their electrical properties. Here we present the first electrical resistance tomography (ERT) measurements on large-area graphene samples, obtained with a dedicated measurement setup and reconstruction software. The outcome of an ERT measurement is a map of the graphene electrical conductivity. The same setup allows to perform van der Pauw (vdP) measurements of the average conductivity. We characterised the electrical conductivity of chemical-vapour deposited graphene samples by performing ERT, vdP and scanning terahertz time-domain spectroscopy (TDS), the last one by means of a commercial instrument. The measurement results are compared and discussed, showing the potential of ERT as an accurate and reliable technique for the electrical characterization of graphene samples.

The electrical properties of graphene can be assessed with different techniques. Contact methods, like the inline four-point probe (4PP) and the van der Pauw (vdP) methods, achieve the highest measurement accuracy. The 4PP method even allows for some spatial resolution, but it is destructive on graphene<sup>1–3</sup>. Conversely, if supported by appropriate models, contactless scanning methods, like terahertz time-domain spectroscopy (TDS) and Raman spectroscopy, can provide indirect measurements of conductivity with higher spatial resolution than the 4PP method.

A way to perform accurate and spatially resolved electrical measurements is the *electrical resistance tomography* (ERT). This technique generates a map of the electrical conductivity of the interior of a two- or three-dimensional sample from a set of four-terminal resistance measurements performed at its boundary<sup>4–6</sup>. Applications of ERT and, more generally, of its equivalent in the ac regime, the *electrical impedance tomography* (EIT), are found in many research and industrial fields. For example, in civil engineering, ERT/EIT can be applied to multi-phase flow detection and measurement<sup>7,8</sup>. In geology, the technique can be applied to the exploration of soils and aquifers<sup>9,10</sup>. Medical applications of EIT, the most studied, include real-time visual monitoring of breathing and cardiac activity<sup>6</sup>. A system for the recognition of wrist gestures has been recently reported<sup>11</sup>.

ERT/EIT implementations with fast multiplexers and analogue-to-digital converters achieve millisecond measurement times, thus allowing real-time imaging with reconstruction rates of the order of 100 Hz<sup>8,12,13</sup>. For these applications, the goal is to get high image contrast, to highlight inhomogeneities and to record the temporal evolution of the samples rather than to accurately measure conductivity values. However, since ERT can be considered as a kind of highly-redundant vdP method, accurate quantitative measurements should also be possible: in fact, the authors have recently shown that ERT can provide accurate conductivity maps of thin film samples<sup>14</sup>.


The basis of ERT is the solution of a so-called inverse problem: the two- or three-dimensional conductivity map is obtained from a discrete set of four-terminal resistance measurements. The solution of the inverse problem requires regularisation techniques and dedicated numerical methods: for this purpose, both commercial<sup>15</sup> and open source<sup>16</sup> ERT packages are available.

In the following, we describe a setup, based on commercial electrical instruments and a dedicated measurement fixture, for the measurement of ERT maps on large-area graphene samples. Measurements are performed on large-area graphene samples on an insulating substrate. vdP and TDS measurements are also performed on the same samples and the results are compared.

<sup>1</sup>INRIM — Istituto Nazionale di Ricerca Metrologica, Torino, 10135, Italy. <sup>2</sup>Graphenea, San Sebastián, 20009, Spain.

<sup>3</sup>das-Nano, Tajonar, 31192, Spain. <sup>4</sup>Universidad Pública de Navarra, Campus Arrosadía, Pamplona, 31006, Spain.

<sup>5</sup>Politecnico di Torino, Torino, 10129, Italy. Correspondence and requests for materials should be addressed to A.C. (email: [a.cultrera@inrim.it](mailto:a.cultrera@inrim.it))



**Figure 1.** (a) Photograph of the contact fixture. (b) Side-view drawing of the fixture. (c,d) Details of the 16 spring-loaded electrodes. The fixture accepts  $1 \times 1$  cm samples. A sample is first loaded on a milled plastic support and then the actuator lever is operated to lift the sample until it makes contact with the spring-loaded needles. The electrodes touch the sample at  $500 \mu\text{m}$  from its edges. The diameter of each needle tip is  $40 \mu\text{m}$ . The vertical-rail loading mechanism limits the applied force to  $0.15$  N.

## Methods

**ERT setup.** The input quantities of the ERT method are a set of four-terminal resistances. Their measurement is performed by contacting the sample at its boundary.


A dedicated measurement setup has been implemented. The sample is contacted with  $n = 16$  electrodes using a custom fixture, as shown in Fig. 1.

The four-terminal resistance measurements are performed with the circuit of Fig. 2, consisting of a current source and a voltmeter connected to the electrode array through a relay scanner.

To perform an ERT measurement, a measurement pattern should be defined. A measurement pattern is the sequence of current injecting contact pairs and voltage measurement pairs used to perform the four-terminal resistance measurements. Several different measurement patterns can be considered<sup>17–19</sup>. There are two important aspects that need to be taken into account when choosing a measurement pattern: (i) the spatial resolution depends on the number of resistance measurements generated by the pattern; (ii) the accuracy of the reconstructed conductivity map depends on the accuracy associated to the resistance measurements defined by the pattern. In general, there is a trade-off between these two aspects because patterns that generate a large number of measurements are more affected by the measurement noise<sup>19</sup>.

In our implementation, we employed an *adjacent* pattern: the current  $I$  is injected in a pair of adjacent contacts (e.g., 1–2, with contact  $n$  considered adjacent to contact 1) and the voltage  $V$  is measured across all remaining pairs of adjacent contacts (3–4, 4–5, ...); then, the current is switched to the next adjacent pair (e.g., 2–3) and the voltage measurement is repeated across all other pairs. In total, a set of  $n(n - 3)$  different measurements is obtained.

The current was set to  $100 \mu\text{A}$  to get voltages of the order of tens of microvolt, a level suitable to be measured with high accuracy with the present setup. To check whether this current level was acceptable, a series of measurements with currents ranging from  $10 \mu\text{A}$  to  $100 \mu\text{A}$  was performed. The compatibility of the resistance values obtained at different current levels excluded self-heating effects on the samples, and confirmed the ohmic nature



**Figure 2.** Electrical schematic diagram of the measurement setup. The 16 discs inside the sample area represent the spring-loaded electrodes of Fig. 1. The distance between nearby contacts along an edge is 2 mm, while the distance between nearby contacts at a corner is 2.12 mm. The dash-dotted box represents the switching unit, which includes  $4 \times 8$  relay switches (only a few are drawn). A full (empty) dot represents a closed (open) relay switch. In the present setup, the dc voltmeter is a Keysight 34461A; the dc ammeter is a Keithley K2602B; the switching unit is a Keysight 34933A reed relay matrix in a 34480A host. All instruments are interfaced through an IEEE-488 bus.

of the contacts. To minimise offset and noise, each measurement was performed at currents  $\pm I$  and averaged over 10 repetitions. The total measurement time was about 400 s. The measurements were performed in a shielded and temperature-controlled environment at  $(23.0 \pm 0.5)^\circ\text{C}$ .

All instruments were calibrated on the measurement ranges employed during the experiments. Instrument specifications and measurement repeatability allow to evaluate<sup>20</sup> the combined (type A + B) uncertainty of the four-terminal resistance measurements. The resulting relative uncertainty is less than  $4 \times 10^{-3}$ . In absence of applied magnetic field, the sample can be considered as an  $n$ -terminal reciprocal network, and a validation of the measurements is given by the reciprocity error, the difference between two reciprocal transresistance measurements. Here the relative average reciprocity error is less than  $1 \times 10^{-3}$ .

The measurement setup allows also to perform automated vdP measurements over a large number of vdP contact configurations.

**ERT image reconstruction.** Consider a conductive region  $\Omega$  bounded by the surface  $\Sigma$ . Let  $\sigma(P)$  be the conductivity at each point  $P$  of  $\Omega$ . The electrostatic problem<sup>21</sup> is governed by the Laplace equation

$$\nabla \cdot [\sigma(P)\nabla\phi(P)] = 0, \quad (1)$$

where  $\nabla$  and  $\nabla \cdot$  are, respectively, the gradient and the divergence operators, and  $\phi(P)$  is the electrostatic potential.


The *forward* electrostatic problem consists in determining  $\phi(P)$  when  $\sigma(P)$  is known at each point  $P$  of  $\Omega$  and a set of electrical boundary conditions are given at the surface  $\Sigma$ . The solution to this problem yields also the current density  $\mathbf{J}(P) = -\sigma(P)\nabla\phi(P)$ . The boundary conditions of the ERT forward problem involve  $n$  points on the conductor surface  $\Sigma$ , which we can interpret as  $n$  contacts, to which terminals can be connected. The conductor can be thus considered as an  $n$ -terminal passive electrical network  $\mathcal{N}$ . If the currents  $I_k$ ,  $k = 1, \dots, n$ , through terminals are given, it can be shown<sup>22</sup> that the ERT forward problem has a unique solution  $\phi(P)$  in the volume  $\Omega$  (up to the choice of a terminal reference potential).

The *inverse* electrostatic problem consists instead in determining  $\sigma(P)$  in  $\Omega$  from information on  $\phi(P)$  and  $\mathbf{J}(P)$  at the surface  $\Sigma$ . In the ERT inverse problem, the information is given in the form of a set  $\mathbf{R}$  of four-terminal resistances of  $\mathcal{N}$ ,  $R_{pq,rs} = V_{rs}/I_{pq}$ , with  $p, q, r, s = 1, \dots, n$ , and where  $V_{rs}$  is the open-circuit voltage across terminals  $r$  and  $s$  when current  $I_{pq}$  flows from terminal  $p$  to terminal  $q$  with all the other terminals left open. Since the measurement of  $V_{rs}$  samples  $\phi(P)$  only at discrete points of the surface  $\Sigma$ , the given input information is incomplete and the ERT inverse problem is ill-posed, ill-conditioned and nonlinear<sup>23</sup>. The ill-posed nature of the ERT inverse problem requires a regularisation technique<sup>6,24,25</sup>. Detailed formulations of the ERT problem, and thorough discussions about the existence and uniqueness of a solution, are given in the bibliography<sup>5,6,26,27</sup>.

The ERT map reconstruction here employed is based on the Tikhonov functional<sup>28</sup> [section 5]

$$\hat{\sigma} = \underset{\varsigma}{\operatorname{argmin}} \|\mathbf{R}^F(\varsigma) - \mathbf{R}\|^2 + \lambda^2 \mathcal{R}(\varsigma), \quad (2)$$

where  $\hat{\sigma}$  is the estimate of the conductivity map  $\sigma(P)$ ;  $\varsigma$  is the (map) argument of the functional,  $\|\mathbf{R}^F(\varsigma) - \mathbf{R}\|$  is the norm of the deviation of  $\mathbf{R}^F(\varsigma)$ , the solution of the forward problem for  $\varsigma$ , from  $\mathbf{R}$ . The last term,  $\mathcal{R}(\varsigma)$ , is the



**Figure 3.** Test of the ERT method. Conductivity maps of a FTO sample were measured (a) before and (b) after performing a thin straight cut (red line).

regularisation term and the scalar  $\lambda$  is the regularization parameter. ERT problems are typically solved by finite-element methods<sup>29,30</sup>.

We developed an ERT image reconstruction code based on EIDORS (Electrical Impedance and Diffuse Optical tomography Reconstruction Software), an open source package of functions running on MATLAB and Octave platforms<sup>31</sup>. The code generates a two-dimensional finite-element square mesh (6994 elements) having the same size of the sample, with 16 contacts placed as in the experimental fixture. A point contact model was considered appropriate because of the small size of the physical contacts compared to the mesh element size<sup>32</sup>. The ERT solution  $\hat{\sigma}$  is obtained with an absolute iterative reconstruction approach based on the Gauss-Newton solver available in EIDORS. We employed Tikhonov regularisation with Laplace prior constraint<sup>33</sup>. The strategy employed for the selection of the regularisation parameter  $\lambda$  is the L-curve method<sup>34</sup>.

The finite element solution  $\hat{\sigma}$  is interpolated and rediscritised (with EIDORS routines) on a grid of the same size as the TDS maps ( $100 \times 100$  pixel) to make these directly comparable. The image resolution depends primarily on the amount of available boundary measurements and it is thus limited by the number of contacts. In practice, features smaller than the inter-electrode distance are smeared out<sup>14,35</sup>. Other factors that can affect the image resolution are the mesh density and the amount of regularisation. In our experiments the mesh was dense enough to have no substantial influence on the spatial resolution.

The expression of uncertainty of the conductivity values of an ERT map is an open problem, in particular for the determination of the sensitivity with respect to the input data (the four-terminal resistance measurements) and the specific reconstruction method chosen. Preliminary numerical simulations suggest to assign to the maps presented below a conservative relative uncertainty of a few percent.

A test measurement on a fluorinated tin oxide (FTO) thin film is reported in Fig. 3. The sample, of uniform conductivity, was measured before (Fig. 3a) and after (Fig. 3b) the surface had been damaged with a thin linear cut. The conductivity values of Fig. 3a have a relative standard deviation of 1.6%; the conductivity dip in Fig. 3b has a full width at half maximum (measured over the sample diagonal) of 2.69 mm, to be compared with the average distance between two adjacent contacts of 2 mm. Other test measurements on the same material, with different geometries, are reported in a previous work<sup>14</sup>.


**Time domain terahertz spectroscopy.** In terahertz time-domain spectroscopy, an electromagnetic sub-picosecond pulse is focussed on the sample. The amplitude of the reflected component (*THz waveform*) is measured in the time domain. The Fourier transform of the waveform gives the frequency components of the pulse, which typically span the range from 100 GHz to 5 THz<sup>36–43</sup>.

The measurements were performed with a Onyx TDS scanner, a graphene and 2D material quality inspector developed by das-Nano<sup>44</sup>. A sketch of the system is reported in Fig. 1b of Ladrón *et al.*<sup>45</sup>. A fibre-coupled laser generates femtosecond optical pulses from which pulses are generated and detected by conversion with photoconductive antennas<sup>40–42</sup>. A pump-and-probe scheme allows then to measure the time evolution of the THz waveform. An example of detected signal is shown in Fig. 1d of Ladrón *et al.*<sup>45</sup>. The optical path of the beam includes focussing polyethylene lenses. A mechanical scanning system controls the position of the beam on the sample<sup>46</sup>. The ac conductivity is determined from the Fourier transform of the THz waveform (see Eq. 1 in Buron *et al.*<sup>47</sup>). Fitting the Drude-Smith model<sup>48</sup> to the ac conductivity (see Fig. 2 in Buron *et al.*<sup>49</sup>) allows to recover the dc conductivity of the sample.

For the reported measurements, the system was configured in normal reflection geometry (emitter and detector located on the same side of the sample) with a 25 mm focal length and a bandwidth of up to 5 THz. The broadband pulse includes frequencies from 0.1 THz to 3 THz, yielding an average spatial resolution of  $600 \mu\text{m}$ . However while the stronger beam component is around 0.5 THz, information is also present at the higher frequency that corresponds to a spatial resolution of  $100 \mu\text{m}$ . Hence, a scanning resolution (pixel size) of  $100 \mu\text{m}$  was chosen to avoid any loss of information and possible image aliasing. On  $1 \times 1$  cm samples, this produced  $100 \times 100$  pixel maps.

| Symbol                                     | Meaning  |
|--|--|
| $\sigma_{\text{ERT}}$                      | Local conductivity by ERT  |
| $\sigma_{\text{TDS}}$                      | Local conductivity by TDS  |
| $\overline{\sigma}_{\text{ERT}}$           | Average of $\sigma_{\text{ERT}}$ over the whole sample area                                |
| $\overline{\sigma}_{\text{TDS}}$           | Average of $\sigma_{\text{TDS}}$ over the whole sample area                                |
| $\overline{\sigma}_{\text{ERT}}^{\square}$ | Average of $\sigma_{\text{ERT}}$ over an area of $3.5 \times 3.5$ around the sample centre |
| $\overline{\sigma}_{\text{TDS}}^{\square}$ | Average of $\sigma_{\text{TDS}}$ of $3.5 \times 3.5$ around the sample centre              |
| $\sigma_{\text{vdp}}$                      | Conductivity by vdp  |


**Table 1.** Symbols used in the text.



**Figure 4.** Sample S40: (a) ERT conductivity map and (b) TDS map. The maps have  $100 \times 100$  pixels and the color scale represents the conductivity in. (c) ERT and TDS conductivity distributions. (d) Pixel-to-pixel scatter plot of ERT versus TDS conductivity values. Each dot has coordinates  $(\sigma_{\text{ERT}}, \sigma_{\text{TDS}})$  and the solid line is the quadrant bisector, for which  $\sigma_{\text{ERT}} = \sigma_{\text{TDS}}$ .

**Sample preparation.** The monolayer graphene samples were grown by the authors on a  $18 \mu\text{m}$ -thick copper foil catalyst surface inside a 4-inch chemical vapour deposition (CVD) reactor AIXTRON BM. Before the graphene growth, the copper foil is annealed for 15 min at  $1000^\circ\text{C}$  using a mixture of argon and hydrogen to reduce the native copper oxide and increase the grain size. The graphene growth is performed at  $1000^\circ\text{C}$  for 10 min using a mixture of methane and hydrogen in 1:4 ratio with argon as gas carrier. After the growth phase, the system is cooled down to room temperature under a hydrogen and argon atmosphere. A poly-methyl methacrylate (PMMA) coating is spun on the grown graphene and the copper foil is then etched in an aqueous solution of  $\text{FeCl}_3$ . After the etching, the  $\text{FeCl}_3$  is removed by rinsing the sample in several baths of deionised water.





**Figure 5.** Sample S28: (a) ERT conductivity map and (b) TDS map; the maps have  $100 \times 100$  pixels and the color scale indicates the conductivity in. (c) the ERT and TDS conductivity distributions. (d) the pixel-to-pixel scatter plot of ERT versus TDS conductivity values. Each dot has coordinates  $(\sigma_{ERT}, \sigma_{TDS})$ ; the solid line is the quadrant bisector, for which  $\sigma_{ERT} = \sigma_{TDS}$ .

| Sample | $\sigma_{ERT}^{\square}$ | $\sigma_{ERT}^{\oplus}$ | $\sigma_{TDS}^{\square}$ | $\sigma_{TDS}^{\oplus}$ | $\sigma_{vdP}$    |
|--------|--------------------------|-------------------------|--------------------------|-------------------------|-------------------|
| S40    | 2.531                    | 2.669                   | 2.663                    | 2.565                   | 2.880 [2.38–3.23] |
| S28    | 2.050                    | 1.323                   | 2.214                    | 2.878                   | 1.631 [1.16–2.98] |

**Table 2.** Electrical conductivity obtained with ERT, TDS and vdP methods on samples S40 and S28. Symbols are defined in Table 1. The vdP value  $\sigma_{vdP}$  is measured choosing contacts close to the four corners; the interval includes the values measured with the other electrode configurations. All values are expressed in mS.

Finally, the PMMA/graphene stack is transferred onto a quartz substrate wafer and the PMMA is removed in acetone. The wafer is cut into  $1 \times 1$  cm chips. All measurements are performed after cutting.

The test sample of Fig. 3 is a commercial fluorine-doped tin-oxide film (FTO;  $\text{SnO}_2:\text{F}$ ) on a glass substrate. FTO is highly doped and its electrical behaviour is metallic<sup>14</sup>. A laser scriber was used to define the sample geometry and to cut the defect line of Fig. 3b, which has a length of 4.5 mm and a thickness of about  $200 \mu\text{m}$ .

## Results and Discussion

**Conductivity maps.** The electrical conductivity of the CVD graphene samples was measured with the methods ERT, TDS and vdP. ERT and TDS returned maps of local conductivity values,  $\sigma_{ERT}$  and  $\sigma_{TDS}$ . For each sample, the averages of these maps were computed over the whole sample ( $\sigma_{ERT}^{\square}$ ,  $\sigma_{TDS}^{\square}$ ) and over a square area of  $3.5 \times 3.5$  mm around the sample centre ( $\sigma_{ERT}^{\oplus}$ ,  $\sigma_{TDS}^{\oplus}$ ). The conductivity measured with the vdP method is labelled as  $\sigma_{vdP}$ . For clarity, the symbols are listed in Table 1.

Figures 4 and 5 show the results of the measurements on the graphene samples labelled S40 and S28. Each figure shows the ERT map, the TDS map, the ERT and TDS conductivity distributions, and a scatter plot of the ERT conductivity versus the TDS conductivity for each pixel.

Both ERT and TDS maps show significant conductivity variations across the samples. Similar variations were reported in other works<sup>49–51</sup> and can be related to the quality of the growth process (which affects the grain size<sup>52,53</sup>), to the presence of bi- or multi-layer seeds<sup>54</sup>, to the quality of the transfer process (which can cause wrinkles or cracks<sup>55,56</sup> and leave polymer residues<sup>57</sup>) and to local adsorption of environmental contaminants. The average conductivity values reported in Table 2 range from 1.5 mS to 2.9 mS, a range consistent with the literature on large area CVD graphene<sup>56,58–61</sup>. ERT maps appear more contrasted than TDS ones. Comparisons of the conductivity distributions (Figs 4c and 5c) and of the ERT-TDS pixel scatter plots (Figs 4d and 5d) show that the ERT maps extend to lower conductivity values than the TDS maps. The discrepancy between ERT and TDS maps could be explained by a different sensitivity of the two techniques to line defects of zero conductivity, such as tears, having a width much below the resolution. TDS performs an average over the spot size, whereas ERT is based on global electric current flow paths which are diverted by line defects. Such an effect in TDS maps has been previously reported in the literature<sup>49</sup> [Fig. 3c].

The ERT map of S40 is shown in Fig. 4a.  $\sigma_{\text{ERT}}$  is lower at the top and bottom edges of the sample, and substantially uniform in its interior. The same features can be recognised also in the TDS map of Fig. 4b.  $\sigma_{\text{ERT}}^{\square}$  and  $\sigma_{\text{TDS}}^{\square}$  are in reasonable agreement with a relative difference of 5.1%. If we consider the averages  $\sigma_{\text{ERT}}^{\square}$  (S40) and  $\sigma_{\text{TDS}}^{\square}$  (S40) around the sample centre, where the maps have the best visual match, the agreement slightly improves to 4%. The lower conductivity spots on the sample edge are likely to be due to dicing/transfer defects having zero conductivity. The distribution of  $\sigma_{\text{ERT}}$  (Fig. 4c) actually reaches a zero value, whereas the range of  $\sigma_{\text{TDS}}$  has a narrower span, possibly related to the broader resolution of the TDS method. Concerning S28, the ERT and TDS maps are shown respectively in Fig. 5a,b. The main feature is the presence of two low conductivity spots, one near the sample centre, and one at the bottom right corner. This can be clearly recognised in both the ERT and TDS maps. The discrepancy between  $\sigma_{\text{ERT}}^{\square}$  (S28) and  $\sigma_{\text{TDS}}^{\square}$  (S28) is 7.7%, larger than that obtained for S40. This is reflected in the longer tail in the distribution of  $\sigma_{\text{ERT}}$  (Fig. 5c) for low conductivity values, compared to that of  $\sigma_{\text{TDS}}$ .

**van der Pauw measurements.** Table 2 reports the  $\sigma_{\text{vdP}}$  conductivity measured in the typical configuration, using contacts close to the sample corners. The measurement system, however, allows for many other configurations and the interval of values covered by these measurements is also reported. The vdP method<sup>2</sup> requires samples of homogeneous conductivity (for this ideal case all the measurements in the different contact configurations would give the same value). The spatial sensitivity function of the vdP method has been derived for the square geometry, with contacts positioned at the corners or at the edges<sup>62</sup>, showing that the vdP method is highly sensitive to the conductivity in the central region, and that the sensitivity goes to zero at the sample border. The vdP conductivity  $\sigma_{\text{vdP}}$  (S40) is 13.8% greater than  $\sigma_{\text{ERT}}^{\square}$  (S40) and 7.9% than  $\sigma_{\text{TDS}}^{\square}$  (S40). This is consistent with the ERT map (Fig. 4a), where  $\sigma_{\text{ERT}}$  around the sample centre is greater than that at the border. In sample S28,  $\sigma_{\text{vdP}}$  (S28) is 20.4% less than  $\sigma_{\text{ERT}}^{\square}$  (S28) but 18.8% greater than  $\sigma_{\text{TDS}}^{\square}$  (S28), because S28 has a conductivity dip in the sample centre. The mismatch between the vdP and the ERT measurements can be related to the conductivity inhomogeneities that strongly affect the vdP results. The large intervals given for the vdP measurement in Table 2 are an independent evidence of these inhomogeneities. Note that the reported intervals of the vdP measurements include the values  $\sigma_{\text{ERT}}^{\square}$  and  $\sigma_{\text{TDS}}^{\square}$ . An additional contribution to the mismatch between vdP and the other techniques is due to the position of the contacts, not exactly lying along the sample border. This contribution can be estimated of about 1%<sup>63,64</sup>.

## Conclusion

We have shown that electrical resistance tomography can be an accurate and easy-to-implement technique for the measurement of electrical conductivity maps of large area graphene samples. Being a contact method, the conductivity map can be obtained without referring to a physical conductivity model, and the measurement traceability can be achieved by routine calibration of the electrical instruments employed. The effects of the substrate is negligible as long its resistivity is sufficiently high. The application of the ERT technique is not bound to the size of the samples here considered. With proper fixtures, wafer-size measurements are possible, the ERT spatial resolution being set by the inter-electrode distance. High-throughput, real-time measurements can also be envisaged.

## Data Availability

The data sets generated during and/or analysed during the current study are available from the corresponding author on reasonable request.

## References

- Smits, F. M. Measurement of sheet resistivities with the four-point probe. *Bell Syst. Tech. J.* **37**, 711–718 (1958).
- van der Pauw, L. J. A method of measuring the resistivity and Hall coefficient on lamellae of arbitrary shape. *Philips Tech. Rev.* **20**, 220–224 (1958).
- Miccoli, I., Edler, F., Pfnür, H. & Tegenkamp, C. The 100th anniversary of the four-point probe technique: the role of probe geometries in isotropic and anisotropic systems. *J. Phys.: Condens. Matter* **27**, 223201 (2015).
- Cheney, M., Isaacson, D. & Newell, J. C. Electrical impedance tomography. *SIAM Rev.* **41**, 85–101 (1999).
- Borcea, L. Electrical impedance tomography. *Inverse Prob.* **18**, R99–R136 (2002).
- Holder, D. S. (ed.) *Electrical impedance tomography: methods, history and applications* (CRC Press, 2004).
- Wang, M. *et al.* A high-performance eit system. *IEEE Sensors J.* **5**, 289–299 (2005).
- Heikkinen, L. M. *et al.* Real time three-dimensional electrical impedance tomography applied in multiphase flow imaging. *Meas. Sci. Technol.* **17**, 2083 (2006).
- Huisman, J. *et al.* Advances in spectral electrical impedance tomography (eit) for near-surface geophysical exploration. In *AGU Fall Meeting Abstracts* (2016).
- Lesparre, N., Robert, T., Nguyen, F., Boyle, A. & Hermans, T. 4d electrical resistivity tomography (ert) for aquifer thermal energy storage monitoring. *Geothermics* **77**, 368–382 (2019).



11. Zhang, Y., Xiao, R. & Harrison, C. Advancing hand gesture recognition with high resolution electrical impedance tomography. In *Proceedings of the 29th Annual Symposium on User Interface Software and Technology*, 843–850 (ACM, 2016).
12. Kourunen, J., Savolainen, T., Lehtikoinen, A., Vauhkonen, M. & Heikkinen, L. M. A PXI-based electrical impedance tomography system for industrial use. *Zeszyty Naukowe. Elektryka/Politechnika Łódzka* 69–74 (2009).
13. Rymarczyk, T., Vejar, A., Nita, P. & Tchórzewski, P. Advanced tomographic platform for real-time image reconstruction and biomedical signal analysis. In *2018 International Interdisciplinary PhD Workshop (IIPhDW), May 2018, Swinoujście, Poland*, 186–190 (IEEE, 2018).
14. Cultrera, A. & Callegaro, L. Electrical Resistance Tomography of conductive thin films. *IEEE Trans. Instrum. Meas.* **65**, 2101–2107 (2016).
15. Fouchard, A., Bonnet, S., Hervé, L. & David, O. Flexible numerical platform for electrical impedance tomography. In *COMSOL conference, Grenoble* (2015).
16. Adler, A. & Lionheart, W. R. B. EIDORS: Towards a community-based extensible software base for EIT. In *Proceedings of the 6th Conference on Biomedical Applications of Electrical Impedance Tomography, London* (2005).
17. Dobson, D. C. & Santosa, F. Resolution and stability analysis of an inverse problem in electrical impedance tomography: dependence on the input current patterns. *SIAM J. Appl. Math.* **54**, 1542–1560 (1994).
18. Kolehmainen, V., Vauhkonen, M., Karjalainen, P. A. & Kaipio, J. P. Assessment of errors in static electrical impedance tomography with adjacent and trigonometric current patterns. *Physiol. Meas.* **18**, 289 (1997).
19. Wang, M., Wang, Q. & Karki, B. Arts of electrical impedance tomographic sensing. *Philos. Transactions Royal Soc. A: Math. Phys. Eng. Sci.* **374**, 20150329 (2016).
20. JCGM 100:2008, Evaluation of measurement data—Guide to the expression of uncertainty in measurement. Available online at [www.bipm.org](http://www.bipm.org). (2008).
21. Jackson, J. D. *Classical electrodynamics* (John Wiley & Sons, Ltd, Chichester, UK, 2012).
22. Somersalo, E., Cheney, M. & Isaacson, D. Existence and uniqueness for electrode models for electric current computed tomography. *SIAM J. on Appl. Math.* **52**, 1023–1040 (1992).
23. Lionheart, W. R. B. EIT reconstruction algorithms: pitfalls, challenges and recent developments. *Physiol. Meas.* **25**, 125 (2004).
24. Eldén, L. Algorithms for the regularization of ill-conditioned least squares problems. *BIT Numer. Math.* **17**, 134–145 (1977).
25. Ahmadian, H., Mottershead, J. E. & Friswell, M. I. Regularisation methods for finite element model updating. *Mech. Syst. Sig. Process.* **12**, 47–64 (1998).
26. Calderón, A. P. On an inverse boundary value problem. *Comp. Appl. Math* **25** (2006).
27. Seo, J. K. & Woo, E. J. *Nonlinear Inverse Problems in Imaging*, chap. Electrical Impedance Tomography, 195–249 (John Wiley & Sons, Ltd, Chichester, UK, 2013).
28. Polydorides, N. & Lionheart, W. R. A matlab toolkit for three-dimensional electrical impedance tomography: a contribution to the electrical impedance and diffuse optical reconstruction software project. *Meas. science and technology* **13**, 1871 (2002).
29. Soni, N. K., Paulsen, K. D., Dehghani, H. & Hartov, A. Finite element implementation of Maxwell's equations for image reconstruction in electrical impedance tomography. *IEEE Trans. Med. Imag.* **25**, 55–61 (2006).
30. Rahmat, M. F. & Thuku, I. T. Review of tomographic imaging using finite element method. *Sensors & Transducers* **135**, 1 (2011).
31. Vauhkonen, M., Lionheart, W. R. B., Heikkinen, L. M., Vauhkonen, P. J. & Kaipio, J. P. A MATLAB package for the EIDORS project to reconstruct two-dimensional EIT images. *Physiol. Meas.* **22**, 107 (2001).
32. Vauhkonen, P. J., Vauhkonen, M., Savolainen, T. & Kaipio, J. P. Three-dimensional electrical impedance tomography based on the complete electrode model. *IEEE Transactions on Biomed. Eng.* **46**, 1150–1160 (1999).
33. Vauhkonen, M., Vadasz, D., Karjalainen, P. A., Somersalo, E. & Kaipio, J. P. Tikhonov regularization and prior information in electrical impedance tomography. *IEEE transactions on medical imaging* **17**, 285–293 (1998).
34. Hansen, P. C. & O'Leary, D. P. The use of the L-curve in the regularization of discrete ill-posed problems. *SIAM J. Sci. Comput.* **14**, 1487–1503 (1993).
35. Harrach, B. & Ullrich, M. Resolution guarantees in electrical impedance tomography. *IEEE Trans. Med. Imag.* **34**, 1513–1521 (2015).
36. Mourou, G., Stancampiano, C., Antonetti, A. & Orszag, A. Picosecond microwave pulses generated with a subpicosecond laser-driven semiconductor switch. *Appl. Phys. Lett.* **39**, 295–296 (1981).
37. Auston, D., Cheung, K. & Smith, P. Picosecond photoconducting hertzian dipoles. *Appl. Phys. Lett.* **45**, 284–286 (1984).
38. Grüner, G. & Dahl, C. *Millimeter and submillimeter wave spectroscopy of solids*, vol. 200 (Springer, 1998).
39. Lee, Y.-S. *Principles of terahertz science and technology*, vol. 170 (Springer Science & Business Media, 2009).
40. Yin, X., Ng, B. W.-H. & Abbott, D. *Terahertz imaging for biomedical applications: pattern recognition and tomographic reconstruction* (Springer Science & Business Media, 2012).
41. Zhu, N. & Ziolkowski, R. W. Photoconductive thz antenna designs with high radiation efficiency, high directivity, and high aperture efficiency. *IEEE Transactions on Terahertz. Sci. Technol.* **3**, 721–730 (2013).
42. Lewis, R. A. A review of terahertz sources. *J. Phys. D: Appl. Phys.* **47**, 374001 (2014).
43. Dhillon, S. *et al.* The 2017 terahertz science and technology roadmap. *J. Phys. D: Appl. Phys.* **50**, 043001 (2017).
44. Mackenzie, D. M. A. *et al.* Quality assessment of terahertz time-domain spectroscopy transmission and reflection modes for graphene conductivity mapping. *Opt. Express* **26**, 9220–9229 (2018).
45. Ladrón, E. A. *et al.* Quality inspection of thin film materials US Patent App. 15/539,091 (2018).
46. Boggild, P. *et al.* Mapping the electrical properties of large-area graphene. *2D Materials* **4**, 042003 (2017).
47. Buron, J. D. *et al.* Graphene conductance uniformity mapping. *Nano Lett.* **12**, 5074–5081 (2012).
48. Smith, N. Classical generalization of the drude formula for the optical conductivity. *Phys. Rev. B* **64**, 155106 (2001).
49. Buron, J. D. *et al.* Electrically continuous graphene from single crystal copper verified by terahertz conductance spectroscopy and micro four-point probe. *Nano Lett.* **14**, 6348–6355 (2014).
50. Buron, J. D. *et al.* Graphene mobility mapping. *Sci. Reports* **5**, 12305 (2015).
51. Buron, J. D. *et al.* Terahertz wafer-scale mobility mapping of graphene on insulating substrates without a gate. *Opt. Express* **23**, 30721–30729 (2015).
52. Yu, Q. *et al.* Control and characterization of individual grains and grain boundaries in graphene grown by chemical vapour deposition. *Nat. Mater.* **10**, 443 (2011).
53. Huang, P. Y. *et al.* Grains and grain boundaries in single-layer graphene atomic patchwork quilts. *Nature* **469**, 389 (2011).
54. Han, Z. *et al.* Homogeneous optical and electronic properties of graphene due to the suppression of multilayer patches during CVD on copper foils. *Adv. Funct. Mater.* **24**, 964–970 (2014).
55. Li, X. *et al.* Transfer of large-area graphene films for high-performance transparent conductive electrodes. *Nano Lett.* **9**, 4359–4363 (2009).
56. Cai, C. *et al.* Crackless transfer of large-area graphene films for superior-performance transparent electrodes. *Carbon* **98**, 457–462 (2016).
57. Suk, J. W. *et al.* Enhancement of the electrical properties of graphene grown by chemical vapor deposition via controlling the effects of polymer residue. *Nano Lett.* **13**, 1462–1467 (2013).
58. Reina, A. *et al.* Large area, few-layer graphene films on arbitrary substrates by chemical vapor deposition. *Nano Lett.* **9**, 30–35 (2008).
59. Gomez De Arco, L. *et al.* Continuous, highly flexible, and transparent graphene films by chemical vapor deposition for organic photovoltaics. *ACS Nano* **4**, 2865–2873 (2010).

60. Bae, S. *et al.* Roll-to-roll production of 30-inch graphene films for transparent electrodes. *Nat. Nanotechnol.* **5**, 574 (2010).
61. Wassei, J. K. & Kaner, R. B. Graphene, a promising transparent conductor. *Mater. Today* **13**, 52–59 (2010).
62. Koon, D. W., Heřmanová, M. & Náhlik, J. Electrical conductance sensitivity functions for square and circular cloverleaf van der Pauw geometries. *Meas. Sci. Technol.* **26**, 115004 (2015).
63. Perloff, D. S. Four-point sheet resistance correction factors for thin rectangular samples. *Solid-State Electron.* **20**, 681–687 (1977).
64. Lim, S. H. N., McKenzie, D. R. & Bilek, M. M. M. Van der Pauw method for measuring resistivity of a plane sample with distant boundaries. *Rev. Sci. Instrum.* **80**, 075109 (2009).

## Acknowledgements

The work is part of the European project “GRACE–Developing electrical characterisation methods for future graphene electronics”, code 16NRM01. This project has received funding from the European Metrology Programme for Innovation and Research (EMPIR) programme co-financed by the Participating States and from the European Union’s Horizon 2020 research and innovation programme. The authors thank Vincenzo D’Elia, Emanuele Enrico, Luca Fasolo and Angelo Greco (INRIM) for the technical support, Montserrat Fernández (das-Nano) for supporting the realization of the experiments, and Alex López (das-Nano) for supporting the development of the Onyx software architecture.

## Author Contributions

A.C. and L.C. conceived and designed the ERT experiments. D.S. engineered the ERT contact fixture. A.Z., A.Ce. and O.T. prepared the samples; D.E. developed the measurement protocols for the Onyx system and performed reflection THz-TDS measurements. A.Co. implemented the physical models in the Onyx software. I.A. has provided scientific guidance in the physical models and validation of the results. A.C., A.R.S. and L.C. analysed the experimental results. A.C., L.C. and M.O. wrote the main manuscript and prepared all the figures. All authors reviewed the manuscript.

## Additional Information

**Competing Interests:** The authors declare no competing interests.

**Publisher’s note:** Springer Nature remains neutral with regard to jurisdictional claims in published maps and institutional affiliations.



**Open Access** This article is licensed under a Creative Commons Attribution 4.0 International License, which permits use, sharing, adaptation, distribution and reproduction in any medium or format, as long as you give appropriate credit to the original author(s) and the source, provide a link to the Creative Commons license, and indicate if changes were made. The images or other third party material in this article are included in the article’s Creative Commons license, unless indicated otherwise in a credit line to the material. If material is not included in the article’s Creative Commons license and your intended use is not permitted by statutory regulation or exceeds the permitted use, you will need to obtain permission directly from the copyright holder. To view a copy of this license, visit <http://creativecommons.org/licenses/by/4.0/>.

© The Author(s) 2019